

Certificate of compliance

Applicant: KOSTAL Solar Electric GmbH

Hanferstraße 6

79108 Freiburg im Breisgau

Germany

Product: Grid-tied photovoltaic (PV) inverter

Model: PIKO CI 30

Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with EN 50549-2:2019 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Connection rule: EN 50549-2:2019:

Requirements for generating plants to be connected in parallel with distribution

networks - Part 2:

Connection to a MV distribution network - Generating plants up to and including

Type B

The power generating units, stated in the certificate, were tested and certified according to the technical guidelines referenced to the grid connection regulation. The electrical characteristics fulfil the requirements of the grid connection regulation:

- 4.4 Normal operating range
- 4.5 Immunity to disturbances
- 4.6 Active response to frequency deviation
- 4.7 Power response to voltage changes
- 4.8 EMC and power quality
- 4.9 Interface protection
- 4.10 Connection and starting to generate electrical power
- 4.11 Ceasing and reduction of active power on set point

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: 20TH0371_EN50549-2_0 Certification scheme: NSOP-0032-DEU-ZE-V01

Certificate number: U20-0791 Date of issue: 2020-10-12



Thomas Lammel



Certification body of Bureau Veritas Consumer Products Services Germany GmbH accredited according to DIN EN ISO/IEC 17065

A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH



Extract from test report according to EN 50549-2

Nr. 20TH0371_EN50549-2_0

Type Approval and declaration of compliance with the requirements of EN 50549-2						
Product description:	Grid-tied photovoltaic inverter					
Unit / Type:	PIKO CI 30					
Input DC voltage range [V]:	180-1000					
MPP DC voltage range [V]:	180-960					
Full-Load MPP DC voltage range [V]:	480-800					
Input DC current [A]:	max. 37,5 / 37,5					
Nominal output AC voltage [V]:	400, 3~ + N + PE; 50 Hz					
Max. output AC current [A]:	48					
Nominal Output AC current [A]:	43,5					
Nominal active output power [kW]:	30,0					
Max. apparent output power [kVA]:	33,0					
Firmware version:	V30KTLD3					
Software version:	3001					

Description of the structure of the power generation unit:

The input and output are protected by Varistors to Earth. The unit is providing EMC filtering at the output toward mains. The unit does not provide galvanic separation from input to output (transformerless). The output is switched off redundant by the high power switching bridge and a two relays. This assures that the opening of the output circuit will also operate in case of one error.



Extract from test report according to EN 50549-2

Nr. 20TH0371_EN50549-2_0

Parameter Table



Parameter list of PIKO CI 30

1. Information regarding the power generating unit

Type designation	Rated power [kW]	Rated active current [A] (at cosφ = 1)
PIKO CI 30	30,0	43,5

2. Parameter set during the measurement

If no noted otherwise the following standard parameters were used during the measurement.

All adaptations to the standard parameters used during the measurement were documented in the EN50549-2 test report.

3. Main Components of the regulating system

Main components of the control system with firmware and software					
Main component(s) of the control system					
Firmware version	V30KTLD3				
Software version	3001				

4. Relevant parameters for the electrical behaviour

No.	Name	Description	Unit	Setting range		Default value		
				Min.	Max.	(acc. to parameter set)		
General parameter settings (rated values or reference values)								
1	Pn	Rated active power	kW	parameter n	ot adjustable	PIKO CI 30: 30		
2	Smax	Max apparent power	kVA	parameter n	ot adjustable	PIKO CI 30: 33,0		
3	Un	Rated voltage	V	parameter not adjustable		400		
4	In	Rated current	Α	parameter n	ot adjustable	PIKO CI 30: 43,5		
5	Fn	Rated frequency	Hz	parameter n	ot adjustable	50		
4.4.2	4.4.2 Operating frequency range							
6	47Hz – 49.0Hz duration	47Hz – 49.0Hz duration		Time period for operation is greater than 30min				
7	49Hz – 51.0Hz duration	49Hz –51.0Hz duration		Time period	for operation	is unlimited		

F.2 BUREAU VERITAS CPS Germany – Parameter list / V01 05/19 Page 1/8



Extract from test report according to EN 50549-2

Nr. 20TH0371_EN50549-2_0



No.	Name	Description	Unit	Setting Min.	g range Max.	Default value (acc. to parameter set)				
8	51Hz – 52.0Hz duration	51Hz –52.0Hz duration		Time period for operation is greater than 30min						
4.4.3	4.4.3 Minimal requirement for active power delivery at underfrequency									
9	Minimal active power at underfrequency	Minimal active power at underfrequency Not derating at	% Pn	parameter n	ot adjustable	100%Pn				
		underfrequency								
4.4.4	Continuous oper	ating voltage range								
10	Voltage Range Lower limit	Voltage Range Lower limit	p.u	parameter n	ot adjustable	0.85Un				
11	Voltage Range Upper limit	Voltage Range Upper limit	p.u	parameter n	ot adjustable	1.1Un				
4.5.2	Rate of change o	f frequency (ROCOF) immuni	ty							
12	ROCOF immunity	ROCOF immunity	Hz/s	parameter n	ot adjustable	2Hz/s				
4.5.4	Low voltage ride Over-voltage ride Zero current mo	• ,	ed generating	g plants						
12	FRT function Enable/Disable	FRT function setting		Enable/Disal	ble	Enable				
13	FRT Mode	FRT Mode setting		0: zero curre 1: full grid su		Full grid support mode				
14	K_Factor_pos	K_factor for positive sequence	0.1	0	6.0	2.0				
15	K_Factor_neg	K_factor for negative sequence	0.1	0	6.0	2.0				
16	Grid voltage protection shield	Enable or disable grid voltage protection during FRT		Enable/Disal	ble	Enable				
17	LVRT triggering shreshold	LVRT triggering shreshold	p.u.	0.1Un	Un	0.85Un				
18	HVRT triggering shreshold	HVRT triggering shreshold	p.u.	Un 1.4Un		1.15Un				
19	Zero current mode triggering threshold	Triggering threshold When zero current mode activation	p.u.	0	1.5Un	0.7Un				
20	Grid voltage jump triggering threshold	Triggering threshold when voltage sudden change	p.u.	0.05Un	1.0Un	0.05Un				

F.2 BUREAU VERITAS CPS Germany – Parameter list / V01 05/19 Page 2/8

Extract from test report according to EN 50549-2

Nr. 20TH0371_EN50549-2_0



No.	Name	Description	Unit	Setting Min.	g range Max.	Default value (acc. to parameter set)	
21	FRT exit hysteresis threshold	FRT exit hysteresis threshold		parameter not adjustable		0.01Un	
22	LVRT diagram	LVRT volt-time diagram		parameter n	ot adjustable	Time(s),	U(p.u.)
						0.5	0.2
						8	0.85
						180	0.9
23	HVRT diagram	HVRT volt-time diagram		parameter n	ot adjustable	Time(s),	U(p.u.)
						0.5	1.2
						8	1.15
						180	1.1
4.6.1	Power response	to overfrequency					
24	P(f) curve function	Enable or disable power response of overfrequency		Enable/Disal	ble	Enable	
25	Droop	Power droop gradient.	0.1%	2.0%	12%	5 %	
		(over frequency power reduction use the samp droop value)		(means 100%Pref/ 16.67%Pref Hz) /Hz)		(means 40%Pref/Hz)	
		$\left(s = \frac{\Delta f}{f_{\rm n}} \middle/ \frac{\Delta P}{P_{\rm ref}}\right)$					
26	Start frequency P(f) (Start of frequency regulation - power reduction)	Start frequency P(f) (Start of frequency regulation - power reduction)	Hz	50.0Hz	55.0Hz	50.2Hz	
27	Quit frequency of overfrequency derating	Quit frequency of overfrequency derating	Hz	50.0Hz	55.0Hz	50.2Hz	
29	Power recovery gradient of P(f)	Active power gradient after deactivation of P(f) curve		parameter not adjustable		9%/min	
30	Over frequency regulation Pref	Pref of over frequency regulation		parameter not adjustable		Pmom	
4.7.2	Capabilities						
32	Q_Mode	Reactive power control mode		0x00:pure active cos phi specification		ons	
				0x01: Cos p specificatio	ns		
				0x02: Q sp	ecifications		

F.2 BUREAU VERITAS CPS Germany – Parameter list / V01 05/19 Page 3/8



Extract from test report according to EN 50549-2

Nr. 20TH0371_EN50549-2_0



No.	Name	Description	Unit	Settin Min.	g range Max.	Default value (acc. to parameter set)
				0x03: Cos characteris		
				0x04: Q(U) characteris		
				0x09: Q(P) characteris		
33	Reactive control settling time (PT1 Behaviour)	Reactive power settling time (3τ)	s	1s	120s	10s
Q_mc	de: Cos phi sp	ecifications				
34	Cos phi set	Cos phi setpoint	0.001	0.8pf	1.0pf	1.0pf
	point	(+) over-excited				
		(-) under-excited				
Q_mc	de: Q specifica	ations				
35	Q specifications	Set reactive power percentage (Q/Pn)	%Pn	0%	110%	0%
		(+) over-excited				
		(-) under-excited				
Q_mc	ode: Cos phi(P)					
36	Cos phi(P) Node 1 Power percentage	cosφ(P) characteristic Node 1 Power percentage (P/Pn)	% Pn	0%	100%	0%
37	Cos phi(P)	cosφ(P) characteristic	0.001 pf	0.8pf	1.0pf	1.0pf
	Node 1 cosφ	Node 1 cosφ		(-) under- excited		
38	Cos phi(P) Node 2 Power percentage	cosφ(P) characteristic Node 2 Power percentage (P/Pn)	% Pn	0%	100%	20%
39	Cos phi(P)	cosφ(P) characteristic	0.001 pf	0.8pf	1.0pf	1.0pf
	Node 2 cosφ	Node 2 cosφ		(-) under- excited		
40	Cos phi(P) Node 3 Power percentage	cosφ(P) characteristic Node 3 Power percentage (P/Pn)	% Pn	0%	100%	50%
41	Cos phi(P)	cosφ(P) characteristic	0.001 pf	0.8pf	1.0pf	1.0pf
	Node 3 cosφ	Node 3 cosφ		(-) under- excited		

F.2 BUREAU VERITAS CPS Germany – Parameter list / V01 05/19 Page 4/8



Extract from test report according to EN 50549-2

Nr. 20TH0371_EN50549-2_0



No.	Name	Description	Unit	Settin	g range	Default value
				Min.	Max.	(acc. to parameter set)
42	Cos phi(P) Node 4 Power percentage	cosφ(P) characteristic Node 4 Power percentage (P/Pn)	% Pn	0%	100%	100%
43	Cos phi(P)	cosφ(P) characteristic	0.001 pf	0.8pf	1.0pf	0.9pf
	Node 4 cosφ	Node 4 cosφ		(-) under- excited		(-) under-excited
Q_mc	ode: Q(U)					
44	Q(U) Node 1	Q(U) characteristic node 1	% Pn	0%	60%	48.4%
	reactive power percentage	Q percentage (Q/Pn)			(+) over- excited	(+) over-excited
45	Q(U) Node 1 voltage percentage	Q(U) characteristic node 1 U percentage (U/Un)	% Un	0%	100%	93%
46	Q(U) Node 2	Q(U) characteristic node 2	% Pn	0%	60%	0%
	reactive power percentage	Q percentage (Q/Pn)			(+) over- excited	
47	Q(U) Node 2 voltage percentage	Q(U) characteristic node 2 U percentage (U/Un)	% Un	0%	100%	97%
48	Q(U) Node 3	Q(U) characteristic node 3 Q percentage (Q/Pn)	% Pn	-60%	0%	0%
	reactive power percentage	Q percentage (Q/FII)		(-) under- excited		
49	Q(U) Node 3 voltage percentage	Q(U) characteristic node 3 U percentage (U/Un)	% Un	100%	140%	103%
50	Q(U) Node 4 reactive power	Q(U) characteristic node 4	% Pn	-60%	0	-48.4%
	percentage	Q percentage (Q/Pn)		(-) under- excited		(-) under-excited
51	Q(U) Node 4 voltage percentage	Q(U) characteristic node 4 U percentage (U/Un)	% Un	100%	140%	107%
Q_mc	ode: Q(P)					
52	Q(P) node 1	Q(P) characteristic node 1	% Pn	-60%	0%	0%
	reactive power percentage	Q percentage (Q/Pn)		(-) under- excited		
53	Q(P) node 1 Power percentage	Q(P) characteristic node 1 P percentage (P/Pn)	% Pn	0%	100%	50%
54	Q(P) node 2	Q(P) characteristic node 2	% Pn	-60%	0%	-5%
	reactive power percentage	Q percentage (Q/Pn)		(-) under- excited		(-) under-excited

F.2 BUREAU VERITAS CPS Germany – Parameter list / V01 05/19 Page 5/8



Extract from test report according to EN 50549-2

Nr. 20TH0371_EN50549-2_0



No.	Name	Description	Unit	Setting range		Default value	
				Min.	Max.	(acc. to parameter set)	
55	Q(P) node 2 Power percentage	Q(P) characteristic node 2 P percentage (P/Pn)	% Pn	0%	100%	60%	
56	Q(P) node 3 reactive power percentage	Q(P) characteristic node 3 Q percentage (Q/Pn)	% Pn	-60% (-) under- excited	0%	-33% (-) under-excited	
57	Q(P) node 3 Power percentage	Q(P) characteristic node 3 P percentage(P/Pn)	% Pn	0%	100%	90%	
58	Q(P) node 4 reactive power percentage	Q(P) characteristic node 4 Q percentage (Q/Pn)	% Pn	-60% (-) under- excited	0	-33% (-) under-excited	
59	Q(P) node 4 Power percentage	Q(P) characteristic node 4 P percentage (P/Pn)	% Pn	0%	100%	100%	
4.7.3	Voltage related a	ctive power reduction(P(U) fu	inction)				
60	P(U) curve enable/disable	Enable or disable P(U) curve		Enable/Dis	able	Enable	
61	P(U) curve triggering shreshold	P(U) curve triggering shreshold	p.u.	Un	1.4Un	1.1Un	
62	P(U) curve active power derating	P(U) curve active power percentage(P/Pn)	%Pn	0%	100%	15%	
4.9.3	Requirements on	voltage and frequency prote	ction				
63	OV Level1 threshold	OV Level1 threshold	p.u.	1.0Un	1.4Un	1.15Un	
64	OV Level1 operate time	OV Level1 operate time	ms	0	600000	150	
65	UV Level1 threshold	UV Level1 threshold	p.u.	0.1Un	1.0Un	0.85Un	
66	UV Level1 operate time	UV Level1 operate time	ms	0	600000	1300	
67	OV Level2 threshold	OV Level2 threshold	p.u.	1.0Un	1.4Un	1.15Un	
68	OV Level2 operate time	OV Level2 operate time	ms	0	60000	150	
69	UV Level2 threshold	UV Level2 threshold	p.u.	0.1Un	1.0Un	0.85Un	
70	UV Level2 operate time	UV Level2 operate time	ms	0	60000	1300	

F.2 BUREAU VERITAS CPS Germany – Parameter list / V01 05/19 Page 6/8



Extract from test report according to EN 50549-2

Nr. 20TH0371_EN50549-2_0



No.	Name	Description	Unit	Setting	g range	Default value
				Min.	Max.	(acc. to parameter set)
71	OV threshold of 10min moving average	OV threshold of 10min moving average	p.u.	1.0Un	1.4Un	1.1Un
72	OF Level1 threshold	OF Level1 threshold	Hz	50Hz	60Hz	52Hz
73	OF Level1 operate time	OF Level1 operate time	ms	0	600000	400
74	UF Level1 threshold	UF Level1 threshold	Hz	40Hz	50Hz	47.5Hz
75	UF Level1 operate time	UF Level1 operate time	ms	0	600000	400
76	OF Level2 threshold	OF Level2 threshold	Hz	50Hz	60Hz	52Hz
77	OF Level2 operate time	OF Leve2 operate time	ms	0	6000	400
78	UF Level2 threshold	UF Level2 threshold	Hz	40Hz	50Hz	47.5Hz
79	UF Level2 operate time	UF Level2 operate time	ms	0	60000	400
4.10.2	Automatic reco	nnection after tripping				
80	Reconnection grid voltage upper limit	Limit value reconnection U<	p.u.	1.0Un	1.4Un	1.1Un
81	Reconnection grid voltage lower limit	Limit value reconnection U>	p.u.	0.1Un	1.0Un	0.9Un
82	Reconnection grid frequency upper limit	Limit value reconnection f<	Hz	50Hz	60Hz	50.2Hz
83	Reconnection grid frequency lower limit	Limit value reconnection f>	Hz	40Hz	50Hz	49.5Hz
84	Active power gradient of reconnection after tripping	Active power gradient when Reconnection after grid trip	%Pn/min	0%	100%	9%
85	Reconnect delay time	Reconnect delay time after protection trigger	s	10s	600s	60s
4.10.3	Starting to gene	rate electrical power				
86	Connection grid voltage upper limit	Limit value connection U<		parameter n	ot adjustable	1.1Un

F.2 BUREAU VERITAS CPS Germany – Parameter list / V01 05/19 Page 7/8



Extract from test report according to EN 50549-2

Nr. 20TH0371_EN50549-2_0



No.	Name	Description	Unit	Setting range		Default value		
				Min.	Max.	(acc. to parameter set)		
87	Connection grid voltage lower limit	Limit value connection U>		parameter n	ot adjustable	0.9Un		
88	Connection grid frequency upper limit	Limit value connection f<		parameter n	ot adjustable	50.1Hz		
89	Connection grid frequency lower limit	Limit value connection f>		parameter n	ot adjustable	49.5Hz		
90	Active power gradient of connection	Active power gradient when first connect to the grid	%Pn /min	0%	100%	100%		
91	First connect delay time	connection time without previous protection trigger	S	10s	600s	60s		
4.11.1	Ceasing active	power						
92	Reaction time of remote tripping	Reaction time of remote tripping	s	parameter n	ot adjustable	0		
4.11.2	4.11.2 Reduction of active power on set point							
93	Max active power	Max active power feed in	W	0	Pmax	Pmax		
94	Power Derating	Active power Derating (P/Pn)	% Pn	0	110%	110%		
95	Active power change gradient	Active power change gradient	%Pn/s	0.01%Pn/ s	2.0%Pn/s	0.50%Pn/s		

F.2 BUREAU VERITAS CPS Germany – Parameter list / V01 05/19 Page 8/8